

Westchester County Department of Parks, Recreation and Conservation ADA Quick Sheet

Facility/Park Name:Maple Moor	Staff Name: D.Donahoe			Date: 01/4/23	
Quick Checklist	YES	NO	Number	Comment	Solution
PARKING					
1) Is there at least one route	X				
from the parking lot that					
does not require the use					
of stairs?					
2) Are there parking spaces?	X				
3) How many total spaces?	174				
4) Are there accessible	X				
spaces?					
5) How many total	4				
accessible spaces?					
6) Is there a sign at each	X				
accessible parking space?					
7) Of the accessible spaces,	X				
is at least one a van					
accessible?					
ENTRANCE					
8) Is the main entrance to	X			We have 2 accessible entrances	
faciltiy/park accessible?					

Westchester County Department of Parks, Recreation and Conservation ADA Quick Sheet

Facility/Park Name:Maple Moor	Staff Name: D.Donahoe		Date: 01/4/23		
Quick Checklist	YES	NO	Number	Comment	Solution
9) If the main entrance is not accessible, is there an alternative accessible entrance?				N/A we are accessible	
10) Do/does the inaccessible entrance(s) have sign(s) indicating an alternative accessible entrance?				N/A we are accessible	
11) Is the accessible entrance signed with the international symbol of accessibility?	X				
12) Is there a stable, firm and slip-resistant route from the parking lot into the facility/park?	X				
13) Is the route at least 36" wide?	X				
14) Can all objects protruding along the route be detected by a person with a visual disability using a cane?	X				
15) Do curb cuts on the route have curb cuts at drives,	X				

Westchester County Department of Parks, Recreation and Conservation ADA Quick Sheet

Facility/Park Name:Maple Moor	Staff Name: D.Donahoe			Date: 01/4/23	
pariking and dropoffs?					
Quick Checklist	YES	NO	Number	Comment	Solution
RAMPS					
16) Do ramps longer than 6 feet have railings on both sides?	X				
17) Is the width between the railings at least 36 inches?	X				
18) Are ramps non-slip?	X				
RESTROOMS					
19) How many restrooms are in your facility/park?		5			
20) How many are single use/family restrooms?		1			
21) How many are multi-use restrooms?		1			
22) Are pipes below the lavatory insulated or otherwise configured to protect against contact?	X				
23) Can the faucet be oper-					

Westchester County Department of Parks, Recreation and Conservation ADA Quick Sheet

Facility/Park Name:Maple Moor	Staff Name: D.Donahoe			Date: 01/4/23	
ated without tight grasping,	X				
pinching or twisting of the					
wrist?					
24) How many restrooms	1				
are marked accessible?					
Quick Checklist	YES	NO	Number	Comment	Solution
25) In a multi-use restroom,					
are any of the stalls marked				No stalls/ single use	* all bathrooms are brand new,
as accessible?					to code
26) How many are marked	1				
accessible?					
27) In the accessible stall(s),	1				
how many grab bars are					
there?					
28) Can the door be opened	X				
easily?					
29) Are doors equipped with					
accessible handles 48 inches	X				
high or less?					
30) Is the lock operable with	x				
one hand and not require					
grasping, pinching or twisting					
of the wrist?					

Westchester County Department of Parks, Recreation and Conservation ADA Quick Sheet					
Facility/Park Name:Maple Moor	Staff Name:	D.Donahoe		Date: 01/4/23	
31) Does the entry provide	x				
adequate maneuvering space					
for a person using a wheel-					
chair?					