

**Westchester County
Department of Parks, Recreation and Conservation**

Quarterly Fire Prevention Checklist

Fire Prevention Checklist	YES	NO	N/A
1- Smoke alarm(s) are located on each level of the facility and in each quarters. (If present)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2- Smoke alarm(s) are checked and tested monthly.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3 - Smoke alarm batteries are replaced twice a year or immediately when the low battery chirp sounds once a minute. (Date last change of battery) 3/15/23	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
4- Smoke alarm(s) are replaced if it is 10 years old or older. (Age of smoke alarm(s) 6/20/20	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5- Carbon monoxide alarm(s) are located in each facility and on each level if sleeping quarters are present.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6- Carbon monoxide alarm(s) are checked and tested monthly.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
7- Carbon monoxide batteries are replaced twice a year or immediately when the low battery chirp sounds once a minute. (Date last change of battery) 3/15/23	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
8- Carbon monoxide alarms (s) are replaced if it is 10 years old or older. (Age of carbon monoxide alarm(s) 6/20/20	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
9- Flammable liquids are properly labeled and stored in an approved safety container or cabinet.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
10- Fire extinguisher(s) are located in each facility and are properly maintained.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Facility: Croton Point Park

Building: Nature Center

Inspectors Name: Doug Falcone (please print)

Inspectors Signature: DF

Date: 6/1/23