

Westchester County Department of Parks, Recreation and Conservation ADA Quick Sheet

Facility/Park Name:	Staff Name:			Date:	
Croton Point Park/ Croton Gorge	Doug Falcone			1/4/2023	
Quick Checklist	YES	NO	Number	Comment	Solution
PARKING					
1) Is there at least one route from the parking lot that does not require the use of stairs?	Yes				
2) Are there parking spaces?	Yes				
3) How many total spaces?			517		
4) Are there accessible spaces?	Yes				
5) How many total accessible spaces?			14		
6) Is there a sign at each accessible parking space?		No		We have signs in certain locations, every spot has a accessible logo	
7) Of the accessible spaces, is at least one a van accessible?	Yes				
ENTRANCE					
8) Is the main entrance to	Yes				

Westchester County Department of Parks, Recreation and Conservation ADA Quick Sheet

Facility/Park Name:	Staff Name:			Date:	
Croton Point Park/ Croton Gorge	Doug Falcone			1/4/2023	
faciltiy/park accessible?					
Quick Checklist	YES	NO	Number	Comment	Solution
9) If the main entrance is not accessible, is there an alternative accessible entrance?	N/A				
10) Do/does the inaccessible entrance(s) have sign(s) indicating an alternative accessible entrance?	N/A				
11) Is the accessible entrance signed with the international symbol of accessibility?	N/A				
12) Is there a stable, firm and slip-resistant route from the parking lot into the facility/park?	Yes				
13) Is the route at least 36" wide?	Yes				
14) Can all objects protruding along the route be detected by a person with a visual dis-	Yes				

Westchester County Department of Parks, Recreation and Conservation ADA Quick Sheet

Facility/Park Name:	Staff Name:			Date:	
Croton Point Park/ Croton Gorge	Doug Falcone			1/4/2023	
ability using a cane?					
15) Do curb cuts on the route					
have curb cuts at drives,	N/A				
parking and dropoffs?					
Quick Checklist	YES	NO	Number	Comment	Solution
RAMPS					
16) Do ramps longer than 6 feet					
have railings on both sides?	Yes				
17) Is the width between the					
railings at least 36 inches?	Yes				
18) Are ramps non-slip?	No				
RESTROOMS					
19) How many restrooms are					
in your facility/park?			6		
20) How many are single use/			5	1 at park office and 4 in full service cabins	
family restrooms?					
21) How many are multi-use			5		
restrooms?					

Westchester County Department of Parks, Recreation and Conservation ADA Quick Sheet

Facility/Park Name:	Staff Name:			Date:	
Croton Point Park/ Croton Gorge	Doug Falcone			1/4/2023	
22) Are pipes below the lavatory insulated or otherwise configured to protect against contact?	Yes				
23) Can the faucet be operated without tight grasping, pinching or twisting of the wrist?	Yes				
24) How many restrooms are marked accessible?			0	Required Signs	
Quick Checklist	YES	NO	Number	Comment	Solution
25) In a multi-use restroom, are any of the stalls marked as accessible?			0	Required Signs	
26) How many are marked accessible?			0	Required Signs	
27) In the accessible stall(s), how many grab bars are there?			2 or 3		
28) Can the door be opened easily?	Yes				

Westchester County Department of Parks, Recreation and Conservation ADA Quick Sheet

Facility/Park Name:	Staff Name:			Date:	
Croton Point Park/ Croton Gorge	Doug Falcone			1/4/2023	
29) Are doors equipped with accessible handles 48 inches high or less?	Yes				
30) Is the lock operable with one hand and not require grasping, pinching or twisting of the wrist?	Yes				
31) Does the entry provide adequate maneuvering space for a person using a wheel-chair?	Yes				