

Westchester County Department of Parks, Recreation and Conservation ADA Quick Sheet

Facility/Park Name:	Staff Name:	Jene Davis		Date: 01/05/2023	
Willson's Woods					
Quick Checklist	YES	NO	Number	Comment	Solution
PARKING					
1) Is there at least one route	✓				
from the parking lot that					
does not require the use					
of stairs?					
2) Are there parking spaces?	✓				
3) How many total spaces?			137	90-Top lot , 47-Lower Lot	
4) Are there accessible	✓				
spaces?					
5) How many total		8		All at Pool	
accessible spaces?					
6) Is there a sign at each		✓			
accessible parking space?					
7) Of the accessible spaces,	✓				
is at least one a van					
accessible?					
ENTRANCE					
8) Is the main entrance to	✓				
faciltiy/park accessible?					

Quick Checklist	YES	NO	Number	Comment	Solution
9) If the main entrance is not accessible, is there an alternative accessible entrance?	✓				
10) Do/does the inaccessible entrance(s) have sign(s) indicating an alternative accessible entrance?		✓			
11) Is the accessible entrance signed with the international symbol of accessibility?		✓			
12) Is there a stable, firm and slip-resistant route from the parking lot into the facility/park?	✓				
13) Is the route at least 36" wide?	✓				
14) Can all objects protruding along the route be detected by a person with a visual disability using a cane?	✓				
15) Do curb cuts on the route have curb cuts at drives, parking and dropoffs?	✓				

Quick Checklist	YES	NO	Number	Comment	Solution
RAMPS					
16) Do ramps longer than 6 feet have railings on both sides?		✓			
17) Is the width between the railings at least 36 inches?					
18) Are ramps non-slip?	✓				
RESTROOMS					
19) How many restrooms are in your facility/park?			6	2 Womens, 2 Mens, 1 First Aid, 1 Family	
20) How many are single use/family restrooms?			1		
21) How many are multi-use restrooms?			4		
22) Are pipes below the lavatory insulated or otherwise configured to protect against contact?	✓				
23) Can the faucet be operated without tight grasping, pinching or twisting of the wrist?	✓				
24) How many restrooms			0		

are marked accessible?					
Quick Checklist	YES	NO	Number	Comment	Solution
25) In a multi-use restroom, are any of the stalls marked as accessible?		✓			
26) How many are marked accessible?			0		
27) In the accessible stall(s), how many grab bars are there?			2 to 3		
28) Can the door be opened easily?	✓				
29) Are doors equipped with accessible handles 48 inches high or less?	✓			42"	
30) Is the lock operable with one hand and not require grasping, pinching or twisting of the wrist?	✓				
31) Does the entry provide adequate maneuvering space for a person using a wheel- chair?	✓				